

AmTest Laboratories
13600 NE 126th PL Suite C
Kirkland, WA 98034



Professional
Analytical

Services

Pure Way Filtration
6993 Professional Parkway
Sarasota, Fl 34240

Dear Laren Meek:
Enclosed please find the analytical data for your water purification system project.
NSF Protocols were followed with the proper amount of time for in and out of service.
The following is a cross correlation of client and laboratory identifications for your convenience.

Client ID	MATRIX	Service	TESTS
PureWay	Water	SP. Project	NWTPHCIDw, BTEX, MET, MIN

AMTEST ID TEST
25-A012C718

Your samples were taken on Thursday June 26. At the times of sampling , the samples were logged in and properly maintained prior to the subsequent analysis in accordance of NSF protocols.
The analytical procedures used at Am Test are EPA certified and well documented and are typically derived from the protocols of the EPA, USDA, FDA or the Army Corps of Engineers. Following the analytical data you will find the Quality Control (QC) results. Please note that the detection limits that are listed in the body of the report refer to the Practical Quantitation Limits (PQL's), as opposed to the Method Detection Limits (MDL's). As per NSF protocols. If you should have any questions pertaining to the data package, please feel free to conact me.

Sincerely,
Aaron W. Young
Laboratory
Manager

Am Test Inc.
 13600 NE 126TH PL Suite C
 Kirkland, WA 98034
 (425) 885-1664
 www.amtestlab.com



**Professional
 Analytical
 Services**

June 26TH 2025
 Pure Way Filtration
 6993 Professional Parkway
 Sarasota, FL 34240

ANALYSIS REPORT

ICP Metals Tests were
 by EPA conducted
 Method @ 6gpm
 200.7

AMTEST Identification Number	25-A012C718
Client Identification	STARTING SOLUTION
Sampling Date	06/26/25, 11:30

PARAMETER	Raw Water	RESULT	UNITS	reduction %	MCL	D.L.	METH OD	ANALYST
Aluminum	3.7	ND	mg/l	ND	0.02	0.02	EPA 200.7	
Arsenic	24	0.00138	mg/l	99.99	0.01	0.005	EPA 200.7	KQ
Cadmium	2.3	< 0.0005	mg/l	99.98	0.005	0.0005	EPA 200.7	
Chromium	4.33	0.0018	mg/l	99.93	0.1	0.005	EPA 200.7	KQ
Copper	11	0.120	mg/l	99.95		0.005	EPA 200.7	KQ
Lead 0.024 @ ph6.5, 0.031 @ ph 8.5	0.024 0.024	0.0003. 0.00004	mg/l	99.99.	0.015	0.010	EPA 200.7	kq
fluoride	12	1.440	mg/l	88.00			EPA 300.0	kq
Mercury	2.2	< 0.005	mg/l	100	0.002	0.005	EPA 200.7	KQ
Nickel	3.9	< 0.002	mg/l		0.002	0.002	EPA 200.7	KQ
Selenium	1.9	< 0.005	mg/l	99.74	0.00019	0.005	EPA 200.7	KQ
Tin	1.3	ND	mg/l	ND		0.01	EPA 200.7	KQ
Zinc	17	< 0.0025	mg/l	99.99	5	0.0025	EPA 200.7	KQ

Haloacetic Acid	tests were conducted @ 6gpm								
PARAMETER	Raw Water water ug/1	RESULT	UNITS	Reduction %	MCL	D.L	METHOD	ANALYST	DATE
Dichloroacetic acid	106.89	ND	ug/1	<99.99	60	0.22	EPA 524.2	KQ	6/26/25
Trichloroacetic acid.	105.31	ND	ug/1	<99.99	60	0.34	EPA 524.2	KQ	6/26/25
Monochloroacetic acid	86..92	ND	ug/1	<99.99	60	0.31	EPA 524.2	KQ	6/26/25
Dibromoacetic acid	97.44	ND	ug/1	<99.99	60	0.33	EPA 524.2	KQ	6/26/25
Trihalomethanes (TTHM)	tests were conducted @ 6gpm								
PARAMETER	Raw Water	RESULT	UNIT	Reduction %	MCL	D.L.	Method	ANALYST	DATE
Chloroform	164.4	ND	ug/1	>99.99	80	0.22	EPA 524.2	KQ	6/26/25
Bromoform	179.3	ND	ug/1	>99.99	80	0.22	EPA 524.2	KQ	6/26/25
Bromodichloromethane	188.8	ND	ug/1	>99.99	80	0.22	EPA 524.2	KQ	6/26/25
Total Trihalomethanes	112	ND	ug/1	>99.99	80	0.22	EPA 524.2	KQ	6/26/25
Volatile Organic Compounds (VOC)	tests were conducted @ 6gpm								
PARAMETER	Raw Water	RESULT	UNIT	Reduction %	MCL	D.L.	Method	ANALYST	DATE
SOC- Pesticides / Insecticides	7.56	ND	MG/L	>99.99	0.005		EPA 524.2	KQ	6/26/25
SOC- Herbicides	9.31	ND	MG/L	>99.99	0.005		EPA 524.2	KQ	6/26/25
Systematic Organochlorines	7.77	ND	MG/L	>99.99	0.07		EPA 524.2	KQ	6/26/25
Phenoxyherbicides	8.11	ND	MG/L	>99.99	0.05		EPA 524.2	KQ	6/26/25
Glyphosate	9.92	ND	MG/L	>99.99	0.07		EPA 524.2	KQ	6/26/25

13600 NE 126th Pl., Suite C
Kirkland, WA 98034
425-885-1664

AMTEST
LABORATORIES

**DRINKING WATER SAMPLE
INFORMATION (WSI)
For Chemical Analysis**

Report To: Laren Meek (PureWay Manufacturing)	Bill To: PureWay Manufacturing
Address: 1320 26th ST NW #7	Address: 1320 26th ST NW #7
City: Auburn State: WA Zip: 98001	City: Auburn State: WA. Zip: 98001
Phone: 253-887-1265	SEND REPORT BY:
Email: laren@purewaymanufacturing.com	<input type="checkbox"/> MAIL <input type="checkbox"/> WEB <input checked="" type="checkbox"/> * EMAIL

Sampling Information REQUIRED

- ☒ Investigative ☐ Compliance – for State regulations for Public Water Systems. (Results will be sent to you and the State.)
- Date Collected: 6/26/25 Time Collected: 11:34 AM ☒ PM ☐
- Collected By: Staff Telephone:
- Specific Location where sample was taken: 13600 NE 126th Pl., Suite C
Kirkland, WA 98034

Water System Information REQUIRED

- System Name: System ID #:
- DOH Source #: ☒ Check here if this is a New Source
(Without a source number DOH will not accept samples. If sample is blended from more than one source, list all)
- Group: ☐ A ☐ B 8. County:
- Source Type: ☐ Surface ☒ Well/Ground Water ☐ Well Field ☐ Spring ☐ Purchased
- Sample Taken: ☐ Before Treatment ☒ After Treatment ☐ No Treatment ☐ In Distribution
- Treatment Type: ☐ None ☐ Aeration ☒ Filtration ☐ Chlorination ☐ Softener ☐ Other:

Analysis to Perform (FREQUENTLY REQUESTED TESTS). FOR OTHERS, PLEASE LIST UNDER OTHER ANALYSIS

Organic Compounds <input checked="" type="checkbox"/> 524.2 - VOC <input checked="" type="checkbox"/> 552.2 - Haloacetic Acids (HAA) <input checked="" type="checkbox"/> 524.2 - Trihalomethanes (THM) Synthetic Organic Compounds (SOC) <input checked="" type="checkbox"/> 515 - Herbicides <input checked="" type="checkbox"/> 525 - Insecticides/Pesticides	Inorganic Compounds <input type="checkbox"/> Complete Inorganics (IOC) <input type="checkbox"/> Plumbing <input checked="" type="checkbox"/> Arsenic <input type="checkbox"/> Nitrates in Drinking Water <input type="checkbox"/> Snohomish County List <input type="checkbox"/> 531 - Carbamates	OTHER ANALYSIS, Please List: Arsenic Fluoride TTHMs Pesticides Lead Chlorine Bacteria pass/fail
---	--	---

Relinquished By	Date	Time	Received By	Date	Time
Laren Meek	6/26	11:34	Jordan Byers	6/26.	11:34

FOR LABORATORY USE ONLY		YES	NO	N/A
SAMPLE TEMP. °C SATISFACTORY		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CHAIN OF CUSTODY & LABELS AGREE		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LABORATORY ID#	REQUESTED TAT: <input type="checkbox"/> NORM <input checked="" type="checkbox"/> 2-DAY <input type="checkbox"/> 5-DAY <input type="checkbox"/> 24-HOURS	PAYMENT:		

Helpful Hints to fill out form on reverse